



**Corporate Accreditation No 63**  
**Accredited for compliance with ISO/IEC 17025 - Testing**



## Analytical Report 246960

**Issue Date:** 27/06/2021  
**Issued By :** Sydney Water Laboratory Services

**Delivery Address:** Sydney Water Corporation  
51 Hermitage Rd  
West Ryde NSW 2114  
**Telephone:** (02) 9800 6935  
**Email:** [analyticalservices@sydneywater.com.au](mailto:analyticalservices@sydneywater.com.au)

**Attention:** Victor Papierniak-Wojtowicz  
**Customer:** Cobar Shire Council  
**Customer ID:** ZCSC

**Address:** PO Box 223, Cobar NSW 2835  
**Telephone:** 6836 5800  
**Email:** [victor.papierniak@cobar.nsw.gov.au](mailto:victor.papierniak@cobar.nsw.gov.au)

### CONTENTS

1. Sydney Water Approved Signatory
2. Sample Summary
3. Analytical results
4. Comments
5. Laboratory QC results

### **Sydney Water Approved Signatory**

Jeya Gajendran, Clean & Waste Water Analyst  
Greta Haddad, Nutrients Laboratory Supervisor

Ricardo Quintana, Clean & Waste Water Analyst

Jack Kabulo, Microbiology Analyst

Where a result is required to meet a compliance limit or specification the associated uncertainty must be considered. Uncertainty estimates are available for all accredited test results.

**SAMPLE SUMMARY**

<u>Client Sample ID</u>	<u>Sample Number</u>	<u>Sampling Procedure</u>	<u>Date Sampled</u>	<u>Date Received</u>	<u>Date Authorised</u>	<u>Description</u>
POINT 1 POLISHER	L21055885	1	16/06/2021	17/06/2021	26/06/2021	(EW)
POINT 2 TURKEYS	L21055886	1	16/06/2021	17/06/2021	26/06/2021	(EW)
SPLITTER BOX 1	L21055887	1	16/06/2021	17/06/2021	25/06/2021	(EW)
SPLITTER BOX 2	L21055888	1	16/06/2021	17/06/2021	25/06/2021	(EW)
INLET	L21055889	1	16/06/2021	17/06/2021	25/06/2021	(EW)

**Sampling procedures**

- 1 Samples analysed as received.
- 2 Samples collected as per FS procedures SAWI 070, Excluding Oil & Grease which is collected as per clients instructions.
- 3 Samples collected as per FS procedures SAWI 070.
- 4 Results reported as received from WNSW.

**ANALYTICAL RESULTS**

<b>Client Sample ID</b>		POINT 1 POLISHER	POINT 2 TURKEYS	SPLITTER BOX 1	SPLITTER BOX 2	INLET			
<b>Sampled Date</b>		16/06/2021 07:45:00 AM	16/06/2021 08:00:00 AM	16/06/2021 07:35:00 AM	16/06/2021 07:30:00 AM	16/06/2021 07:35:00 AM			
<b>Sample Number</b>		L21055885	L21055886	L21055887	L21055888	L21055889			
<b>CHEMISTRY</b>									
WC12MET : Conductivity									
Conductivity (mS/m)	mS/m	80.2	83.9	-	-	-			
Date of Performance	DD/MM/YY	17/06/21	17/06/21						
WC17NS : Biological oxygen demand									
BOD5	mg/L	5	4	230	21	310			
Date of Performance	DD/MM/YY	18/06/21	18/06/21	18/06/21	18/06/21	18/06/21			
WC26NS500 : Grease									
Oil & Grease	mg/L	<5	<5	-	-	-			
Date of Performance	DD/MM/YY	18/06/21	18/06/21						
WC44NS : Determination of Total, Fixed & Volatile Suspended Solids									
Total Suspended Solids	mg/L	7	2	-	-	-			
Date of Performance	DD/MM/YY	23/06/21	23/06/21						
<b>MICRO</b>									

"-" = Not required or refer to Laboratory comment

<b>Client Sample ID</b>	POINT 1 POLISHER	POINT 2 TURKEYS	SPLITTER BOX 1	SPLITTER BOX 2	INLET			
<b>Sampled Date</b>	16/06/2021 07:45:00 AM	16/06/2021 08:00:00 AM	16/06/2021 07:35:00 AM	16/06/2021 07:30:00 AM	16/06/2021 07:35:00 AM			
<b>Sample Number</b>	L21055885	L21055886	L21055887	L21055888	L21055889			

**MICRO**

## MI01 : Faecal Coliforms and/or E. coli by Membrane Filtration

E.coli	CFU/100mL	-	8	-	-	-		
Faecal Coliform	CFU/100mL	-	8	-	-	-		
Date of Performance	D/M/Y H:M		17/06/21 14:31					

**NUTRIENTS**

## NU102 : Nitrogen &amp; Phosphorus

Total Nitrogen	mg/L	10.2	6.64	-	-	-		
Total Phosphorus	mg/L	1.24	0.930	-	-	-		
Date of Performance	DD/MM/YY	22/06/21	22/06/21					

**COMMENTS**

<u>Sample ID</u>	<u>Comment Level</u>	<u>Method</u>	<u>Test</u>	<u>Comment</u>
L21055886	Method	MI01	-	Result confirmed. Sample analysed outside recommended holding time of 24Hrs.

**Analysis**

MI01

**Analysis Requirements**

Faecal Coliforms and/or E.Coli: all results are presumptive unless indicated otherwise.

"-" = Not required or refer to Laboratory comment

**LABORATORY QC RESULTS**

N/A - Not Applicable

PQL - Practical Quantitation Limit

LOQ - Limit of Quantification

RPD - Relative Percent Difference

SPIKE/Positive Control - Addition of a known amount and concentration

Duplicate Precision = Accepted - Result 2 within 95% confidence limits of result 1

Duplicate Precision = Outlier - Result 2 outside 95% confidence limits of result 1

Duplicate Precision = Not calculated - Result is outside test range

LOQ	Blank	Positive Control <i>Acceptance Criteria</i>	Negative Control <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	Precision <i>Acceptance Criteria</i>
<b>MI01 [Membrane Filtration]E.coli</b>						
<1 CFU/100mL	<1	Accepted	Accepted	8	5	Accepted
<b>MI01 [Membrane Filtration]Faecal Coliform</b>						
<1 CFU/100mL	<1	Accepted	Accepted	8	5	Accepted

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
<b>NU102 Total Nitrogen</b>						
<0.05 mg/L	<0.05	0.92 <i>0.88 - 1.12 mg/L</i>	106 % Recovery <i>80 - 120 % Recovery</i>	0.31	0.30	B <i>0 - 0 %</i>
<b>NU102 Total Phosphorus</b>						
<0.002 mg/L	<0.002	0.051 <i>0.045 - 0.055 mg/L</i>	89 % Recovery <i>80 - 120 % Recovery</i>	0.011	0.011	B <i>0 - 0 %</i>
<b>WC12MET Conductivity (mS/m)</b>						
<0.1 mS/m	F	140.7 <i>139.3 - 143.3 mS/m</i>	E			
<b>WC17NS BOD5</b>						
<2 mg/L	<2	220 <i>139 - 257 mg/L</i>	E	230	240	4.26 % <i>0 - 20 %</i>

LOQ	Blank	Control <i>Acceptance Criteria</i>	Spike <i>Acceptance Criteria</i>	Duplicate1	Duplicate2	RPD <i>Acceptance Criteria</i>
<b>WC26NS500 Oil &amp; Grease</b>						
<5 mg/L	<5	92 85.1 - 101.5 mg/L	E			
<b>WC44NS Total Suspended Solids</b>						
<2 mg/L	<2	52 42.5 - 57.5 mg/L	E	6200	6200	0.00 % 0 - 20 %

Extra Note:

F: Blank is not applicable for this analyte

E: Spike is not applicable for this analyte

DUPLICATE Total Phosphorus B: Duplicate RPD reject criteria is not applicable, results are <10 times LOQ